

BASICS OF THE THEORY OF ADAPTIVE IDENTIFICATION FOR AUTOMATION OF MULTI- CONNECTED OBJECTS

Kholmatov Umid Sadirdinovich

*Associate Professor of the Department of Transport Logistics,
Andijan State Technical Institute, Uzbekistan, Andijan*

*E-mail address: umid.xolmatov.76@mail.ru,
<https://orcid.org/0000-0003-2295-502X>*

Annotation: The article proposes solutions to the problem of using the theory of adaptive identification for automation of multiply connected objects and shows the possibilities of applying the theory of adaptive identification of multiply connected objects using the example of wastewater treatment plants.

Keywords: Discrete systems, drainage and treatment facilities, control of multiply connected objects, adaptive identification.

Introduction

It is known that numerous tasks of managing production processes and complex installations, which include chemical and biological wastewater treatment, are multi-connected objects that require a transition from automation of individual processes to automation of production complexes.

Automation of industrial complexes. leads to the need to take into account the interconnectedness of the input and output coordinates of individual processes, and, consequently, the structural links between them. The lack of sufficiently complete a priori information about the object, the laws of distribution of random parameters and random influences makes it necessary to apply the theory of adaptive identification. In the future, adaptive identification of multiply connected objects will be understood as the determination of the parameters and structure of objects under conditions of initial uncertainty, based on the results of monitoring the change in input and output values during normal operation. From this point of view, of particular interest are the electric power systems of drainage and treatment facilities, in which the frequency and voltage, active and reactive power flows, the performance of turbocompressors of pumping stations are simultaneously regulated, and according to the technological mode they are treated as multi-connected objects with separate control channels, operating modes [1-2].

Methods

The task of adaptive identification arises due to the fact that, in the general case, the internal and external influence that acts on the object is of a random nature. For water treatment facilities as objects [3], this randomness is due to the random nature of the disturbing moments and other factors caused by the uneven distribution of pump motor power, the instability of pressure in turbocompressors from cycle to cycle, the concentration of activated sludge, the dose of active chlorine, etc [4, 6-8]. For treatment facilities, such impacts are: filling of sedimentation tanks and aerotanks, failure of one of the symmetrically located engines and pumps, etc.

It is easy to determine the distribution laws for each of these factors separately [5], but it is almost impossible to determine the resulting distribution law for the entire set of factors, and,

accordingly, the identifiable object parameters that depend on them. In this regard, the problem of identifying multiply connected objects is reduced to the problem of adaptive identification. Currently, there is no complete theory of adaptive identification of multiply connected objects. In this article, some questions of the theory of adaptive identification of multiply connected objects containing forward and reverse cross-links are presented.

Results and Discussion

Generalization of the equation of dynamics of multiply connected objects.

Let us describe processes in multiply connected objects of a system of linear inhomogeneous l -th order differential equations with r unknown variables $x_1, x_2, \dots, x_r$ of the argument t with constant coefficients

$$\sum_{j=1}^r a_{ij}(D)x_j = \sum_{j=1}^r b_{ij}(D)v_j \quad (1)$$

where the set of coordinates $\bar{x} = \{x_1, x_2, \dots, x_r\}$; $\bar{v} = \{v_1, v_2, \dots, v_r\}$ - vectors - columns of object state and control, respectively; i - number of a separate channel; $D = d/dt$ - differentiation operator; $a_{ij}(D), b_{ij}(D)$ - are polynomials in D , that have the form

$$a_{ij}(D) = a_{ij}^{(l)} D^l + a_{ij}^{(l-1)} D^{l-1} + \dots + a_{ij}^{(1)} D + a_{ij}^{(0)}; \quad (2)$$

$$b_{ij}(D) = b_{ij}^{(l_1)} D^{l_1} + b_{ij}^{(l_1-1)} D^{l_1-1} + \dots + b_{ij}^{(1)} D + b_{ij}^{(0)};$$

Here $i, j = 1, 2, \dots, r$; l, l_1 - the order of the polynomial of the coefficients a and b , respectively; r is the number of separate channels of the controlled object. It is assumed that the number of direct cross-links is equal to the number of reverse ones; the order of differential equations of reverse cross-links is equal to the order of differential equations of direct cross-links. These assumptions do not reduce the generality of the problem, since in the presence of any other options and combinations of cross-couplings, as well as the order of differential equations, it is reduced to special cases. Let us introduce numerous matrices of operator coefficients [3-4]:

$$A(D) = \|a_{ij}(D)\|;$$

$$B(D) = \|b_{ij}(D)\|; \quad (3)$$

or expanded

$$A(D) = \begin{vmatrix} a_{11}(D) & a_{12}(D) & \dots & a_{1r}(D) \\ a_{21}(D) & a_{22}(D) & \dots & a_{2r}(D) \\ \dots & \dots & \dots & \dots \\ a_{r1}(D) & a_{r2}(D) & \dots & a_{rr}(D) \end{vmatrix}; \quad (4)$$

$$B(D) = \begin{vmatrix} b_{11}(D) & b_{12}(D) & \dots & b_{1r}(D) \\ b_{21}(D) & b_{22}(D) & \dots & b_{2r}(D) \\ \dots & \dots & \dots & \dots \\ b_{r1}(D) & b_{r2}(D) & \dots & b_{rr}(D) \end{vmatrix};$$

Sloping

$$A_k = \|a_{ij}^{(k)}\| \quad (i, j = 1, 2, \dots, r, \quad (5)$$

$$B_q = \|b_{ij}^{(q)}\| \quad q = 0, 1, 2, \dots, l_1),$$

one can represent multiple matrices $A(D)$ in $B(D)$ as polynomials with matrix coefficients

$$A(D) = A_l D^l + A_{l-1} D^{l-1} + \dots + A_1 D + A_0;$$

$$B(D) = B_{l_1} D^{l_1} + B_{l_1-1} D^{l_1-1} + \dots + B_1 D + B_0; \quad (6)$$

Then, in matrix form, the system of differential equations (1) takes the form

$$\sum_{k=0}^l A_k D^k X = \sum_{q=1}^{l_1} B_q D^q \bar{u} \quad (7)$$

In expanded form, for any separate channel, one can write

$$\sum_{k=0}^l \sum_{j=1}^r a_{ij}^{(k)} D^k x_j = \sum_{q=0}^{l_1} \sum_{j=1}^r b_{ij}^{(q)} D^q u_j \quad (8)$$

Let us rewrite equation (8) in a difference form (in a recurrent form):

$$x_i[n] = \sum_{k=0}^l \sum_{j=1}^r c_{ij}^{(k)} x_i[n-k] + \sum_{q=1}^{l_1} \sum_{j=1}^r d_{ij}^{(q)} u[n-q] \quad (9)$$

The matrix coefficients of the equations are interconnected by relations [1-2, 5].

$$c_{ij}^{(l-k)} = - \sum_{v=0}^k a_{ij}^{(l-v)} (-1)^{k-v} c_{l-v}^{k-v};$$

$$d_{ij}^{(l_1-q)} = - \sum_{v=0}^q a_{ij}^{(l_1-v)} (-1)^{q-v} c_{l_1-v}^{q-v};$$

where

$$c_{l-v}^{k-v} = \frac{(1-v)!}{(k-v)!(l-k)!};$$

$$c_{l_1-v}^{q-v} = \frac{(1_1-v)!}{(q-v)!(l_1-k)!};$$

For a controlled object in the presence of only direct cross-links, equation (9) has the form

$$x_i[n] = \sum_{m=1}^l c_{ii}^{(m)} x_i[n-m] + \sum_{j=1}^r \sum_{m=1}^S d_{ij}^{(m)} v_j[n-m], \quad (9.a)$$

and in the presence of only inverses -

$$x_i[n] = \sum_{j=1}^r \sum_{m=1}^S c_{ij}^{(m)} x_i[n-m] + \sum_{m=1}^l d_{ij}^{(m)} v_i[n-m], \quad (9.6)$$

In some cases, some of the coefficients $c_{ij}^{(m)}$ and $d_{ij}^{(m)}$ may be equal, which corresponds to the absence of any links.

Conclusion

The above algorithms allow solving problems from the transition of automation of individual processes to automation of industrial complexes, and determine the possibilities of applying the theory of adaptive identification of multiply connected objects, as well as consider complex issues of compiling identification algorithms by using an iterative probabilistic method.

References

1. Kholmatov U. et al. Static and dynamic characteristics of optoelectronic discrete converters for automatic measurement of displacements and dimensions //EPJ Web of Conferences. – EDP Sciences, 2025. – Vol. 321. – P. 03001.
2. Kholmatov U. S. et al. Characteristics of optoelectronic discrete displacement converters with hollow and fiber light guides //E3S Web of Conferences. – EDP Sciences, 2024. – Vol. 471. – P. 06015.
3. Shipulin Yu. G. et al. Optoelectronic converter for automatic measurements of displacements and dimensions // World of measurements. – 2013. – No. 1. – P. 41-43.
4. Kholmatov U. The possibility of applying the theory of adaptive identification to automate multi-connected objects //The American Journal of Engineering and Technology. – 2022. – Vol. 4. – No. 03. – P. 31-38.
5. Kholmatov U. Optimization of mathematical model of optoelectronic discrete displacement converter //scientific and technical journal machine building. – 2022. – No. 2. – P. 74-82.

6. O.T.Almatayev, U.S.Kholmatov, R.K.Azimov. Reflective optoelectronic converters for automation of liquid and gas flowmeter testing units. BelGUT... - 2014.
7. Kholmatov U. Determination of the main characteristics of optoelectronic discrete displacement transducers with hollow and fiber fiber //scientific and technical journal machine building. – 2022. – No. 4. – pp. 160-168.
8. Kholmatov U. Determination of static characteristics of optoelectronic discrete displacement transducers with hollow and fiber fiber // scientific and technical journal "Mashinostroenie". – 2024. – No. 4. – pp. 180-187.